



**+ BÜRKLE
SCHÖCK**

Northbrook, Illinois • (847) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

 **Underwriters Laboratories Inc.®**

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 032701- E216181

ISSUE DATE: 3-27-01

Page 1 of 2

Issued to: Bürkle & Schöck Transformatoren GmbH
Gewebestrasse 38
70565 Stuttgart Germany

Report Reference: E216181- March 30, 2001


This is to Certify that representative samples of: Component - Class 155 (F), System Electrical Insulation designated BRU-1.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: United States UL1446
Canadian National Standards CSA, Standard C22.2
No. 0-M91.

Additional Information: See Addendum

Only those products bearing the UL Classification Marking should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Marking includes: UL in a circle symbol  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

LOOK FOR THE UL CLASSIFICATION MARKING ON THE PRODUCT

Engineer: 
Patricia Harding
Underwriters Laboratories Inc.

Review Engineer: 
Kenneth McKinney
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service



**+ BÜRKLE
SCHÖCK**

Northbrook, Illinois • (847) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 032701- E216181
ISSUE DATE: 3-27-01

Page 2 of 2

System Designation BRU-1	Insulation Class 155 (F)	Maximum Temperature 155°C hot spot	Indoor yes	Outdoor (Enclosed) yes	Maximum Voltage 600 V
-----------------------------	-----------------------------	---------------------------------------	---------------	---------------------------	--------------------------



Engineer:

Patricia Harding
Patricia Harding
Underwriters Laboratories Inc.

Review Engineer:

Kenneth McKinney
Kenneth McKinney
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service